

DRAFT TEST CERTIFICATE

Materials - Manufactured & Tested as per Specification No. IEC: 61111:2009

Test Report No.: xxxxx, Dated xxxxx

Customer's Name: Trading & Development Company for Machinery and Equipment Ltd. (REDA)

Order No.: & Date: xxxxx, Dated xxxxx

Description: Electrical Insulating Mats as per IEC 6111:2009 Class 4

Dimension: 5.0mm Thick x 1M Wide x 10M Length

Colour: Black

Antiskid Design: Top - Fine Ribbed & Bottom – Textured

Lot No.: xxxxx

Quantity: 10 Rolls (100 SQM)

| Sl. No. | Tests | Unit | Requirement | Actual | Remarks |
|---------|--|------|-------------------------------------|-----------------|---------|
| 1. | <u>Dimensions</u> | | | | |
| 1.a. | a) Length ($\pm 2\%$) | mm | 10000 | 10031 | OK |
| 1.b. | b) Width ($\pm 2\%$) | mm | 1000 | 1010 | OK |
| 1.c. | c) Thickness ($\pm 10\%$) | mm | 5.00 | 5.08 | OK |
| 2. | <u>Mechanical Tests</u> | | | | |
| 2.a. | a) Mechanical Puncture Resistance Test | N | >70 | 91.84 | OK |
| 2.b. | b) Slip Resistance Test | N | >50 | 58 | OK |
| 3. | <u>Dielectric Tests</u> | | | | |
| 3.a. | Ac Proof Voltage Test | KV | Shall withstand 40 KV. for 1 Mins. | Withstood 40 KV | OK |
| 4.a. | Ac Dielectric Strength Test | KV | Shall reach 50 KV. without failure. | Reached 50 KV | OK |

CIN - U25209WB2017PTC220480

COW MATS | INSULATION MATS | RUBBER SHEETS | RUBBER HOSES | CONVEYOR & V-BELTS



KOLKATA

63J, Mahanirban Road, 1st Floor,
Kolkata, West Bengal - 700 029



DELHI NCR

SPL-1, RIICO Industrial Area,
Bhiwadi, Rajasthan - 301 019




UAE

Duratuf Products FZE
AFZ B-1, Ajman Free Zone

| | | | | | |
|---|--|---|--|-------|----|
| 5. | <u>Chemical Resistance Test</u> | | | | |
| 5.a | Ageing Test (168hrs. At 70°C) Puncture Resistance | N | Min. 80% of 2a > 73.47 | 87.51 | OK |
| 5.b. | Acid Resistance Test After immersion in 32° Baume Sulphuric acid at 25°C for 8 hours Puncture Resistance | N | Min. 75% of 2a > 68.88 | 79.34 | OK |
| 7. | Oil Resistance Test After immersion in 100 Hydraulic oil at 70° for 24 hours Puncture Resistance | N | Min. 75% of 2a > 68.88 | 73.48 | OK |
| 8. | <u>Thermal Test</u> | | | | |
| | a) Flame Retardance Test | Flame does not reach any point on a 50mm diameter circle | Flame did not reach any point on 50mm diameter from the center of the test piece | OK | |
| | b) Low Temperature Resistance Test | No Crack, Tear or Breakdown | No crack, tear or breakdown observed. | OK | |
| Conclusion/Remarks: Certified that the above materials have been manufactured and tested as per Specification No. IEC: 61111:2009 & latest amendment. The results obtained are satisfactory in all respects. | | | | | |

For, Duratuf Products Private Limited



Authorized Signatory

CIN - U25209WB2017PTC220480

COW MATS | INSULATION MATS | RUBBER SHEETS | RUBBER HOSES | CONVEYOR & V-BELTS



KOLKATA

63J, Mahanirban Road, 1st Floor,
Kolkata, West Bengal - 700 029



DELHI NCR

SPL-1, RIICO Industrial Area,
Bhiwadi, Rajasthan - 301 019



UAE

Duratuf Products FZE
AFZ B-1, Ajman Free Zone